

Trade Effluent ETP - Summary-2015 (Average Values)														
ENV-R-02											Flow			
Month-Year	pH	TSS	TDS	Phosphate	Ammoniacal Nitrogen	Nitrate Nitrogen	COD	Oil & Grease	Total Kjeldahl Nitrogen	Residual Chlorine	K-1 (M3/Day)	K-8 (M3/Month)	K-8 (M3/Day)	Total (K-1 to K-8) (M3/Day)
Jan-15	7.3	64	1422	3.4	32	5.9	132	5.5	39	0.2	1514	10430	336	1850
Feb-15	7.4	60	1226	3.2	26	5.6	134	5.5	33	0.1	1702	9636	344	2046
Mar-15	7.4	63	1326	3.2	27	6.0	129	5.2	35	0.1	1597	12078	390	1987
Apr-15	7.4	69	1547	3	28	6	151	5	36	0.1	1516	10448	348	1864
May-15	7.5	72	1610	4	26	6	134	6	36	0.1	1389	9953	321	1710
Jun-15	7.4	64	1572	3	28	6	145	6	38	0.1	1394	14961	499	1893
Jul-15														
Aug-15														
Sep-15														
Oct-15														
Nov-15														
Dec-15														
Average	7.4	65	1450	3	28	6	138	5	36	0.1	1519	11251	373	1892
MPCB Consent Limits	6.0 to 8.5	100	2100	5	50	10	250	10	100	1	3878			
Parameters	pH	TSS (mg/litre)	TDS (mg/litre)	Phosphate (mg/litre)	Ammoniacal Nitrogen (mg/litre)	Nitrate Nitrogen (mg/litre)	COD (mg/litre)	Oil & Grease (mg/litre)	Total Kjeldahl Nitrogen	Total Residual Chlorine as CL2 (mg/litre)	Flow (K-1 to K-8) M3/Day			