



# GADARK LAB PVT. LTD.

INDUSTRIAL ANALYSTS & CONSULTANTS

LAB. : H-54, Additional M.I.D.C. Kudal, Taluka - Kudal, District - Sindhudurg - 416 525

Tel. : (02362) 223519 • email : info@gadark.in / gadarklab@vsnl.com

OFF. : 15, Hindustan Kohinoor Industrial Complex, L.B.S.Marg, Vikhroli (West), Mumbai - 83.


Tel No. : 022-25777069/70 • Fax - 022-2577 4545

## TEST CERTIFICATE

Report No.	GPW/DW/0696/14	Report Date	17/06/2014
Organisation	M/s. DEEPAK FERTILISERS AND PETROCHEMICALS CORP. LTD. PLOT K - 1, MIDC INDUSTRIAL AREA, TALOJA, A. V. 410 208, DIST. - RAIGAD.		
Lab Reference No.	1406-1111		
Your Letter Dated	---		
Sample Collected By	Gadark Lab Pvt. Ltd.	Date of Sample Collection	11/06/2014
Sample Analysed By	Omkar Dhond	Sample Analysed On	12/06/2014
Sample Description	Ground Water Sample Near Ammonia Tank		
Standard Specifications	IS 10500 / 2012		

Parameters	Units	Test Result	Standard Specifications		Methods
			Requirement Acceptable Limit	Permissible Limit in the Absence of Alternate Source	
<b>ESSENTIAL CHARACTERISTICS :</b>					
Colour (Pt. Scale)	Colour Unit	< 0.1	5.0 Max.	15.0 Max.	APHA 2120 B
Odour	---	Odourless	Agreeable	Agreeable	IS 3025 Part V 1983
Taste	---	Agreeable	Agreeable	Agreeable	APHA 2160 A
Turbidity	NTU	1.9	1.0 Max.	5.0 Max.	APHA 2130 B
pH	---	6.24	6.5 - 8.5	No Relaxation	APHA 4500 H <sup>+</sup>
Total Hardness as CaCO <sub>3</sub>	mg/ltr	340	00.0 Max.	600.0 Max.	APHA 2340 C
Iron	mg/ltr	0.16	0.3 Max.	No Relaxation	APHA 3500 Fe B
Chlorides	mg/ltr	64.54	250.0 Max.	1000.0 Max.	APHA 4500 Cl <sup>-</sup> B
Residual Free Chlorine	mg/ltr	Nil	0.2 Min.	1.0 Max.	APHA 4500 Cl B
<b>DESIRABLE CHARACTERISTICS :</b>					
Total Dissolved Solids	mg/ltr	392	500.0 Max.	2000.0 Max.	APHA 2540 C
Calcium	mg/ltr	64.13	75.0 Max	200.0 Max	APHA 3500 Ca B
Copper	mg/ltr	< 0.001	0.05 Max.	1.5 Max.	APHA 3111 B & C
Manganese	mg/ltr	< 0.001	0.10 Max.	0.30 Max.	APHA 3111 B
Sulphate	mg/ltr	8.2	200.0 Max.	400.0 Max.	APHA 4500 SO <sub>4</sub> <sup>2-</sup>
Nitrate	mg/ltr	0.018	45.0 Max.	No Relaxation	APHA 4500 NO <sub>3</sub> B
Fluoride	mg/ltr	< 0.001	1.0 Max.	1.5 Max.	APHA 4500 F <sup>-</sup>
Phenolic Compounds	mg/ltr	< 0.001	0.001 Max.	0.002 Max.	IS 3025
Mercury	mg/ltr	< 0.001	0.001 Max.	No Relaxation	APHA 3112 B & C
Cadmium	mg/ltr	< 0.001	0.003 Max.	No Relaxation	APHA 3500 Cd
Selenium	mg/ltr	< 0.001	0.01 Max.	No Relaxation	APHA 3114 B
Arsenic	mg/ltr	< 0.001	0.01 Max.	0.05 Max	APHA 3114 B
Cyanide	mg/ltr	< 0.001	0.05 Max.	No Relaxation	APHA 4500 E
Lead	mg/ltr	< 0.001	0.01 Max.	No Relaxation	APHA 3111 B & C
Zinc	mg/ltr	0.019	5.0 Max.	15.0 Max.	APHA 3111 B
Anionic Detergents [as MBAS]	mg/ltr	< 0.001	0.2 Max.	1.0 Max	APHA 5540
Chromium [Cr <sup>6+</sup> ]	mg/ltr	< 0.001	0.05 Max.	No Relaxation	APHA 3500 Cr B
Polynuclear Aromatic Hydrocarbon	mg/ltr	< 0.001	---	---	APHA 6431 B
Pesticides	mg/ltr	< 0.001	Absent	0.001 Max	APHA 6630 BC
Mineral Oil	mg/ltr	< 0.001	0.5 Max.	No Relaxation	APHA 5520 B
Alkalinity	mg/ltr	16.24	200.0 Max.	600.0 Max.	APHA 2320 B
Aluminium	mg/ltr	< 0.001	0.03 Max.	0.2 Max.	APHA 3111 B
Boron	mg/ltr	< 0.001	0.5 Max.	1.0 Max.	APHA 4500 B-B

For GADARK LAB PVT. LTD.

  
[B. S. RANE]  
DIRECTOR

  
CHECKED BY



# GADARK LAB PVT. LTD.

INDUSTRIAL ANALYSTS & CONSULTANTS

LAB.: H-54, Additional M.I.D.C. Kudal, Taluka - Kudal, District - Sindhudurg - 416 525

Tel.: (02362) 223519 • email: info@gadark.in / gadarklab@vsnl.com

OFF.: 15, Hindustan Kohinoor Industrial Complex, L.B.S.Marg, Vikhroli (West), Mumbai - 83

Tel No.: 022-25777069/70 • Fax - 022-2577 4545

## TEST CERTIFICATE

Report No.	GPW/DW/0695/14	Report Date	17/06/2014
Organisation	M/s. DEEPAK FERTILISERS AND PETROCHEMICALS CORP. LTD. PLOT K - 1, MIDC INDUSTRIAL AREA, TALOJA, A. V. 410 208, DIST. - RAIGAD.		
Lab Reference No.	1406-1110		
Your Letter Dated	---		
Sample Collected By	Gadark Lab Pvt. Ltd.	Date of Sample Collection	11/06/2014
Sample Analysed By	Omkar Dhond	Sample Analysed On	12/06/2014
Sample Description	Ground Water Sample Near IPA Plant		
Standard Specifications	IS 10500 / 2012		

Parameters	Units	Test Result	Standard Specifications		Methods
			Requirement Acceptable Limit	Permissible Limit in the Absence of Alternate Source	
<b>ESSENTIAL CHARACTERISTICS :</b>					
Colour (Pt. Scale)	Colour Unit	10	5.0 Max.	15.0 Max.	APHA 2120 B
Odour	---	Odourless	Agreeable	Agreeable	IS 3025 Part V 1983
Taste	---	Agreeable	Agreeable	Agreeable	APHA 2160 A
Turbidity	NTU	56.2	1.0 Max.	5.0 Max.	APHA 2130 B
pH	---	6.81	6.5 - 8.5	No Relaxation	APHA 4500 H*
Total Hardness as CaCO <sub>3</sub>	mg/ltr	350	00.0 Max.	600.0 Max.	APHA 2340 C
Iron	mg/ltr	0.18	0.3 Max.	No Relaxation	APHA 3500 Fe B
Chlorides	mg/ltr	100.39	250.0 Max.	1000.0 Max.	APHA 4500 Cl <sup>-</sup> B
Residual Free Chlorine	mg/ltr	Nil	0.2 Min.	1.0 Max.	APHA 4500 Cl B
<b>DESIRABLE CHARACTERISTICS :</b>					
Total Dissolved Solids	mg/ltr	462	500.0 Max.	2000.0 Max.	APHA 2540 C
Calcium	mg/ltr	64.13	75.0 Max.	200.0 Max.	APHA 3500 Ca B
Copper	mg/ltr	< 0.001	0.05 Max.	1.5 Max.	APHA 3111 B & C
Manganese	mg/ltr	< 0.001	0.10 Max.	0.30 Max.	APHA 3111 B
Sulphate	mg/ltr	16.8	200.0 Max.	400.0 Max.	APHA 4500 SO <sub>4</sub> <sup>2-</sup>
Nitrate	mg/ltr	0.0030	45.0 Max.	No Relaxation	APHA 4500 NO <sub>3</sub> B
Fluoride	mg/ltr	4.67	1.0 Max.	1.5 Max.	APHA 4500 F <sup>-</sup>
Phenolic Compounds	mg/ltr	< 0.001	0.001 Max.	0.002 Max.	IS 3025
Mercury	mg/ltr	< 0.001	0.001 Max.	No Relaxation	APHA 3112 B & C
Cadmium	mg/ltr	< 0.001	0.003 Max.	No Relaxation	APHA 3500 Cd
Selenium	mg/ltr	< 0.001	0.01 Max.	No Relaxation	APHA 3114 B
Arsenic	mg/ltr	< 0.001	0.01 Max.	0.05 Max.	APHA 3114 B
Cyanide	mg/ltr	< 0.001	0.05 Max.	No Relaxation	APHA 4500 E
Lead	mg/ltr	< 0.001	0.01 Max.	No Relaxation	APHA 3111 B & C
Zinc	mg/ltr	0.026	5.0 Max.	15.0 Max.	APHA 3111 B
Anionic Detergents [as MBAS]	mg/ltr	< 0.001	0.2 Max.	1.0 Max.	APHA 5540
Chromium [Cr <sup>6+</sup> ]	mg/ltr	< 0.001	0.05 Max.	No Relaxation	APHA 3500 Cr B
Polynuclear Aromatic Hydrocarbon	mg/ltr	< 0.001	---	---	APHA 6431 B
Pesticides	mg/ltr	< 0.001	Absent	0.001 Max.	APHA 6630 BC
Mineral Oil	mg/ltr	< 0.001	0.5 Max.	No Relaxation	APHA 5520 B
Alkalinity	mg/ltr	318.71	200.0 Max.	600.0 Max.	APHA 2320 B
Aluminium	mg/ltr	< 0.001	0.03 Max.	0.2 Max.	APHA 3111 B
Boron	mg/ltr	< 0.001	0.5 Max.	1.0 Max.	APHA 4500 B-B

For GADARK LAB PVT. LTD.

[B. S. RANE]  
DIRECTOR

CHECKED BY



# GADARK LAB PVT. LTD.

INDUSTRIAL ANALYSTS & CONSULTANTS

LAB. : H-54, Additional M.I.D.C. Kudal, Taluka - Kudal, District - Sindhudurg - 416 525  
Tel. : (02362) 223519 • email : info@gadark.in / gadarklab@vsnl.com

OFF. : 15, Hindustan Kohinoor Industrial Complex, L.B.S.Marg, Vikhroli (West), Mumbai - 83.  
Tel No. : 022-25777069/70 • Fax - 022-2577 4545

## TEST CERTIFICATE

Report No.	GPW/DW/12316/13	Report Date	02/01/2014
Organisation	M/s. DEEPAK FERTILISERS AND PETROCHEMICALS CORP. LTD. PLOT K - 1, MIDC INDUSTRIAL AREA, TALOJA, A. V. 410 208, DIST. - RAIGAD.		
Lab Reference No.	1312-2663		
Your Letter Dated	---		
Sample Collected By	Gadark Lab Pvt. Ltd.	Date of Sample Collection	26/12/2013
Sample Analysed By	Sadashiv Natu	Sample Analysed On	28/12/2013
Sample Description	Ground Water Sample Near IPA Plant		
Standard Specifications	IS 10500 / 2012		

Parameters	Units	Test Result	Standard Specifications		Methods
			Requirement Acceptable Limit	Permissible Limit in the Absence of Alternate Source	
<b>ESSENTIAL CHARACTERISTICS :</b>					
Colour (Pt. Scale)	Colour Unit	< 1.0	5.0 Max.	15.0 Max.	APHA 2120 B
Odour	---	Odourless	Agreeable	Agreeable	IS 3025 Part V 1983
Taste	---	Agreeable	Agreeable	Agreeable	APHA 2160 A
Turbidity	NTU	0.2	1.0 Max.	5.0 Max.	APHA 2130 B
pH	---	7.66	6.5 - 8.5	No Relaxation	APHA 4500 H <sup>+</sup>
Total Hardness as CaCO <sub>3</sub>	mg/ltr	180	300.0 Max.	600.0 Max.	APHA 2340 C
Iron	mg/ltr	0.14	0.3 Max.	No Relaxation	APHA 3500 Fe B
Chlorides	mg/ltr	39.32	250.0 Max.	1000.0 Max.	APHA 4500 Cl <sup>-</sup> B
Residual Free Chlorine	mg/ltr	Nil	0.2 Min.	1.0 Max.	APHA 4500 Cl B
<b>DESIRABLE CHARACTERISTICS :</b>					
Total Dissolved Solids	mg/ltr	258	500.0 Max.	2000.0 Max.	APHA 2540 C
Calcium	mg/ltr	47.29	75.0 Max.	200.0 Max.	APHA 3500 Ca B
Copper	mg/ltr	< 0.001	0.05 Max.	1.5 Max.	APHA 3111 B & C
Manganese	mg/ltr	< 0.001	0.10 Max.	0.30 Max.	APHA 3111 B
Sulphate	mg/ltr	2.8	200.0 Max.	400.0 Max.	APHA 4500 SO <sub>4</sub> <sup>2-</sup>
Nitrate	mg/ltr	0.12	45.0 Max.	No Relaxation	APHA 4500 NO <sub>3</sub> B
Fluoride	mg/ltr	< 0.001	1.0 Max.	1.5 Max.	APHA 4500 F <sup>-</sup>
Phenolic Compounds	mg/ltr	< 0.001	0.001 Max.	0.002 Max.	IS 3025
Mercury	mg/ltr	< 0.001	0.001 Max.	No Relaxation	APHA 3112 B & C
Cadmium	mg/ltr	< 0.001	0.003 Max.	No Relaxation	APHA 3500 Cd
Selenium	mg/ltr	< 0.001	0.01 Max.	No Relaxation	APHA 3114 B
Arsenic	mg/ltr	< 0.001	0.01 Max.	0.05 Max.	APHA 3114 B
Cyanide	mg/ltr	< 0.001	0.05 Max.	No Relaxation	APHA 4500 E
Lead	mg/ltr	< 0.001	0.01 Max.	No Relaxation	APHA 3111 B & C
Zinc	mg/ltr	0.020	5.0 Max.	15.0 Max.	APHA 3111 B
Anionic Detergents [as MBAS]	mg/ltr	< 0.001	0.2 Max.	1.0 Max.	APHA 3111 B
Chromium [Cr <sup>6+</sup> ]	mg/ltr	< 0.001	0.05 Max.	No Relaxation	APHA 3500 Cr B
Polynuclear Aromatic Hydrocarbons	mg/ltr	< 0.001	---	---	APHA 6431 B
Pesticides	mg/ltr	< 0.001	Absent	0.001 Max	APHA 6630 BC
Mineral Oil	mg/ltr	< 0.001	0.5 Max.	No Relaxation	APHA 5520 B
Alkalinity	mg/ltr	180.96	200.0 Max.	600.0 Max.	APHA 2320 B
Aluminium	mg/ltr	< 0.001	0.03 Max.	0.2 Max.	APHA 3111 B
Boron	mg/ltr	< 0.001	0.5 Max.	1.0 Max.	APHA 4500 B - B

For GADARK LAB PVT. LTD.

[B. S. RANE]  
DIRECTOR

CHECKED BY



# GADARK LAB PVT. LTD.

INDUSTRIAL ANALYSTS & CONSULTANTS

LAB. : H-54, Additional M.I.D.C. Kudal, Taluka - Kudal, District - Sindhudurg - 416 525

Tel. : (02362) 223519 • email : info@gadark.in / gadarklab@vsnl.com

OFF. : 15, Hindustan Kohinoor Industrial Complex, L.B.S.Marg, Vikhroli (West), Mumbai - 83.

Tel No. : 022-25777069/70 • Fax - 022-2577 4545

## TEST CERTIFICATE

Report No.	GPW/DW/12317/13	Report Date	02/01/2014
Organisation	M/s. DEEPAK FERTILISERS AND PETROCHEMICALS CORP. LTD. PLOT K - 1, MIDC INDUSTRIAL AREA, TALOJA, A. V. 410 208, DIST. - RAIGAD.		
Lab Reference No.	1312-2664		
Your Letter Dated	---		
Sample Collected By	Gadark Lab Pvt. Ltd.	Date of Sample Collection	26/12/2013
Sample Analysed By	Sadashiv Natu	Sample Analysed On	28/12/2013
Sample Description	Ground Water Sample Near Ammonia Tank Area		
Standard Specifications	IS 10500 / 2012		

Parameters	Units	Test Result	Standard Specifications		Methods
			Requirement Acceptable Limit	Permissible Limit in the Absence of Alternate Source	
<b>ESSENTIAL CHARACTERISTICS :</b>					
Colour (Pt. Scale)	Colour Unit	< 1.0	5.0 Max.	15.0 Max.	APHA 2120 B
Odour	---	Odourless	Agreeable	Agreeable	IS 3025 Part V 1983
Taste	---	Agreeable	Agreeable	Agreeable	APHA 2160 A
Turbidity	NTU	0.3	1.0 Max.	5.0 Max.	APHA 2130 B
pH	---	6.45	6.5 - 8.5	No Relaxation	APHA 4500 H'
Total Hardness as CaCO <sub>3</sub>	mg/ltr	506	300.0 Max.	600.0 Max.	APHA 2340 C
Iron	mg/ltr	0.17	0.3 Max.	No Relaxation	APHA 3500 Fe B
Chlorides	mg/ltr	33.27	250.0 Max.	1000.0 Max.	APHA 4500 Cl-B
Residual Free Chlorine	mg/ltr	Nil	0.2 Min.	1.0 Max.	APHA 4500 Cl B
<b>DESIRABLE CHARACTERISTICS :</b>					
Total Dissolved Solids	mg/ltr	472	500.0 Max.	2000.0 Max.	APHA 2540 C
Calcium	mg/ltr	96.99	75.0 Max.	200.0 Max.	APHA 3500 Ca B
Copper	mg/ltr	< 0.001	0.05 Max.	1.5 Max.	APHA 3111 B & C
Manganese	mg/ltr	< 0.001	0.10 Max.	0.30 Max.	APHA 3111 B
Sulphate	mg/ltr	2.4	200.0 Max.	400.0 Max.	APHA 4500 SO <sub>4</sub> <sup>2-</sup>
Nitrate	mg/ltr	1.21	45.0 Max.	No Relaxation	APHA 4500 NO <sub>3</sub> B
Fluoride	mg/ltr	< 0.001	1.0 Max.	1.5 Max.	APHA 4500 F <sup>-</sup>
Phenolic Compounds	mg/ltr	< 0.001	0.001 Max.	0.002 Max.	IS 3025
Mercury	mg/ltr	< 0.001	0.001 Max.	No Relaxation	APHA 3112 B & C
Cadmium	mg/ltr	< 0.001	0.003 Max.	No Relaxation	APHA 3500 Cd
Selenium	mg/ltr	< 0.001	0.01 Max.	No Relaxation	APHA 3114 B
Arsenic	mg/ltr	< 0.001	0.01 Max.	0.05 Max.	APHA 3114 B
Cyanide	mg/ltr	< 0.001	0.05 Max.	No Relaxation	APHA 4500 E
Lead	mg/ltr	< 0.001	0.01 Max.	No Relaxation	APHA 3111 B & C
Zinc	mg/ltr	0.024	5.0 Max.	15.0 Max.	APHA 3111 B
Anionic Detergents [as MBAS]	mg/ltr	< 0.001	0.2 Max.	1.0 Max.	APHA 3111 B
Chromium [Cr <sup>6+</sup> ]	mg/ltr	< 0.001	0.05 Max.	No Relaxation	APHA 3500 Cr B
Polynuclear Aromatic Hydrocarbons	mg/ltr	< 0.001	---	---	APHA 6431 B
Pesticides	mg/ltr	< 0.001	Absent	0.001 Max	APHA 6630 BC
Mineral Oil	mg/ltr	< 0.001	0.5 Max.	No Relaxation	APHA 5520 B
Alkalinity	mg/ltr	72.8	200.0 Max.	600.0 Max.	APHA 2320 B
Aluminium	mg/ltr	< 0.001	0.03 Max.	0.2 Max.	APHA 3111 B
Boron	mg/ltr	< 0.001	0.5 Max.	1.0 Max.	APHA 4500 B - B

For GADARK LAB PVT. LTD.

  
[B. S. RANE]  
DIRECTOR

  
CHECKED BY



# GADARK LAB PVT. LTD.

## INDUSTRIAL ANALYSTS & CONSULTANTS

LAB.: H-54, Additional M.I.D.C. Kudal, Taluka - Kudal, District - Sindhudurg - 416 525

Tel.: (02362) 223519 • email : info@gadark.in / gadarklab@vsnl.com

OFF. 15, Hindustan Kohinoor Industrial Complex, L.B.S. Marg, Vikhroli (West), Mumbai - 83.

Tel No. : 022-2577 7069 / 70 • Fax - 022-2577 4545.

### TEST CERTIFICATE

Report No	GPW/DW/10194/13	Report Date	23/10/2013
Organisation	M/s. DEEPAK FERTILISERS AND PETROCHEMICALS CORP. LTD. PLOT K - 1, MIDC INDUSTRIAL AREA, TALOJA, A. V. 410 208, DIST. - RAIGAD.		
Lab Reference No.	1310-1119		
Your Letter Dated	---		
Sample Collected By	Gadark Lab Pvt. Ltd.	Date of Sample Collection	11/10/2013
Sample Analysed By	Sadashiv Natu	Sample Analysed On	12/10/2013
Sample Description	Ground Water Sample Near CO <sub>2</sub> Expansion Project - Excavated		
Standard Specifications	IS 10500 / 2012		

Parameters	Units	Test Result	Standard Specifications		Methods
			Requirement Acceptable Limit	Permissible Limit in the Absence of Alternate Source	
<b>ESSENTIAL CHARACTERISTICS :</b>					
Colour (Pt. Scale)	Colour Unit	< 1.0	5.0 Max	15.0 Max	APHA 2120 B
Odour	---	Odourless	Agreeable	Agreeable	IS 3025 Part V 1983
Taste	---	Agreeable	Agreeable	Agreeable	APHA 2160 A
Turbidity	NTU	366	1.0 Max.	5.0 Max.	APHA 2130 B
pH	---	7.94	6.5 - 8.5	No Relaxation	APHA 4500 H'
Total Hardness as CaCO <sub>3</sub>	mg/ltr	590	300.0 Max.	600.0 Max.	APHA 2340 C
Iron	mg/ltr	4.95	0.3 Max.	No Relaxation	APHA 3500 Fe B
Chlorides	mg/ltr	222.58	250.0 Max	1000.0 Max	APHA 4500 Cl <sup>-</sup> B
Residual Free Chlorine	mg/ltr	Nil	0.2 Min.	1.0 Max.	APHA 4500 Cl <sup>-</sup> B
<b>DESIRABLE CHARACTERISTICS :</b>					
Total Dissolved Solids	mg/ltr	786	500.0 Max.	2000.0 Max.	APHA 2540 C
Calcium	mg/ltr	125.04	75.0 Max.	200.0 Max.	APHA 3500 Ca B
Copper	mg/ltr	< 0.001	0.05 Max.	1.5 Max.	APHA 3111 B & C
Manganese	mg/ltr	< 0.001	0.10 Max.	0.30 Max.	APHA 3111 B
Sulphate	mg/ltr	122.14	200.0 Max.	400.0 Max.	APHA 4500 SO <sub>4</sub> <sup>2-</sup>
Nitrate	mg/ltr	0.00816	45.0 Max.	No Relaxation	APHA 4500 NO <sub>3</sub> B
Fluoride	mg/ltr	< 0.001	1.0 Max.	1.5 Max.	APHA 4500 F
Phenolic Compounds	mg/ltr	< 0.001	0.001 Max.	0.002 Max.	IS 3025
Mercury	mg/ltr	< 0.001	0.001 Max.	No Relaxation	APHA 3112 B & C
Cadmium	mg/ltr	< 0.001	0.003 Max.	No Relaxation	APHA 3500 Cd
Selenium	mg/ltr	< 0.001	0.01 Max.	No Relaxation	APHA 3114 B
Arsenic	mg/ltr	< 0.001	0.01 Max.	0.05 Max.	APHA 3114 B
Cyanide	mg/ltr	< 0.001	0.05 Max.	No Relaxation	APHA 4500 E
Lead	mg/ltr	< 0.001	0.01 Max.	No Relaxation	APHA 3111 B & C
Zinc	mg/ltr	0.032	5.0 Max.	15.0 Max.	APHA 3111 B
Anionic Detergents (as MBAS)	mg/ltr	< 0.001	0.2 Max.	1.0 Max.	APHA 3111 B
Chromium [Cr <sup>6+</sup> ]	mg/ltr	< 0.001	0.05 Max.	No Relaxation	APHA 3500 Cr B
Polynuclear Aromatic Hydrocarbons	mg/ltr	< 0.001	---	---	APHA 6431 B
Pesticides	mg/ltr	< 0.001	Absent	0.001 Max	APHA 6630 BC
Mineral Oil	mg/ltr	< 0.001	0.5 Max.	No Relaxation	APHA 5520 B
Alkalinity	mg/ltr	164.0	200.0 Max.	600.0 Max.	APHA 2320 B
Aluminium	mg/ltr	< 0.001	0.03 Max.	0.2 Max.	APHA 3111 B
Boron	mg/ltr	< 0.001	0.5 Max.	1.0 Max.	APHA 4500 B - B

For GADARK LAB PVT. LTD.

  
[B. S. RANE]  
DIRECTOR

  
CHECKED BY

